Town of Clayton POWER OUTAGE REPORT May 2016

General Information			Cause				Customers	
Date	P/U	Feeder / Address	Description	Time Off	Time On	Mins	# Out	Cust Minutes
5/4/2016	U	CENTRAL / 10278 US 70 Bus W	Vines in transformer	11:40am	11:56am	16	1	16
5/6/2016	U	WEST / 217 W. Stallings Street	Bad Underground	9:00am	10:00am	60	1	60
5/15/2016	U	EAST / 121 LaFoy Drive	Bad Underground	7:45pm	9:45pm	120	1	120
5/20/2016	U	SOUTH / 2814 Brittany Woods	Contractor cut tree; damaged TOC property	10:30am	11:30am	60	50	3,000
5/24/2016	U	EAST / 110 Neuse Ridge Drive	Bad Underground	9:00am	10:00am	60	1	60
5/26/2016	U	EAST / 10125 US 70 (Food Lion)	Bad Underground	11:30am	1:45pm	135	3	405

P=Planned U=Unplanned